



भाकअनुप - केन्द्रीय बरानी कृषि अनुसन्धान संस्थान

ICAR - Central Research Institute for Dryland Agriculture

संतोषनगर, सैदाबाद-पोस्ट हैदराबाद ५०००५९ Santoshnagar, Saidabad P.O. Hyderabad 500 059
040-24530161,24530163,2Fax:040-24531802 www.icar-crida.res.in Email : hoa.crida@icar.gov.in



e-F.No: 4-7/(72)/2023-24/CDN
Date:10.05.2024

Sub: Quotations for Electrical Wiring and Lighting Provision for New Car Parking Shed at Gate 2-reg.

Dear Sir(s),

Quotations are invited for following Repair/Works as detailed below:

SL NO	NAME OF THE WORK	PARTICULAR
1	Electrical Wiring and Lighting Provision for New Car Parking Shed at Gate - 2	as per enclosed specifications

TERMS & CONDITIONS

1. The last date for submission of quotation is **03.06.2024**. Rates offered shall be F.O.R. CRIDA, Hyderabad
2. The work shall be carried out as per this Institute Specification and as per the directions of Institute Chairman, IWMC or and Indenting officer and the payment will be made after satisfactory completion of work duly certified by the Indenting Officer
3. Quotations should be submitted in a sealed cover addressed to the Director, Central Research Institute for Dryland Agriculture, Santoshnagar, Saidabad Post, Hyderabad – 500 059. The cover containing quotation should invariably be super scribed.

i. Due on 03.06.2024 16.00 hrs

ii. For supply of material for repairs / masonry / Digging / plastering works etc.

4. The quotation should remain valid for a period of 90 days from the date (due date)
5. No advance payment/delivery against payment is permissible. However, the payment shall be arranged in 15 days from the date of submission of pre-receipted bill in triplicate along with stores.
6. The rates quoted should be net payable for each item/material for delivery at the Institute at the address given above (inclusive of all taxes-GST, packing, forwarding, transport, insurance and excluding rebate/discount etc.)
7. While quoting the rates please mention the following:
 - Approximate time for supply of material from the date of placing order.
 - Guarantee/Warranty/Expiry period
 - Any other condition
8. The participating bidder must submit a copy of GST and PAN card
9. Time allowed for completion of the work 30 days
10. Quotation which do not conform to the above terms and conditions will not be considered. The Director, Central Research Institute for Dryland Agriculture, reserves the right to accept or reject any or all quotations without assigning any reasons thereof.

(V. Sanu)
Administrative Officer

SPECIFICATONS

Electrical Wiring and Lighting Provision for New Car Parking Shed at Gate - 2

SI no	Particular	Nos/Qty	UNITS	Rate Quoted (Rs.)
1	Wiring for light point/ fan point/ exhaust fan point/ call bell point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable in surface /recessed medium class PVC conduit, with modular switch, modular plate, suitable GI box and earthing the point with 1.5 sq.mm FRLS PVC insulated copper conductor single core cable etc. as required. Group C Point	36	Points	
2	Supplying and drawing following sizes of FRLS PVC insulated copper conductor, single core cable in the existing surface/ recessed steel/ PVC conduit as required. 3 x 4 sq. mm	100	Meter	
3	Supply and fixing medium class PVC pipes with accessories making good the same in case of recessed conduits (i) 20mm	75	Meter	
3.1	(ii) 25 mm	75	Meter	
3.2	2.3 Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 V, on surface/ recess, complete with tinned copper bus bar, neutral bus bar, earth bar, din bar, interconnections, powder painted including earthing etc. as required. (But without MCB/RCCB/Isolator) way , Double door	2	Each	
4	Supplying and fixing 5 A to 32 A rating, 240/415 V, 10 kA, "C" curve, miniature circuit breaker suitable for inductive load of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required. Single pole Each 199	8	Each	
4.1	Single pole and neutral	4	Each	
5	Supply Installation Testing and Commissioning of SURFACE mounted LED batten fitting having system output not less than 3600 Lumens and wattage not more than 36W and latest LED technology of consistent light output, stable color performance and colour temperature not less than 5700K and energy saving, suitable for use on 230V, 50Hz, A.C supply including making connections with 1.5sq.mm. FRLS PVC insulated copper conductor single core cable as required.	36	Each	
6	3 Pin 5 / 6A Socket out let	2	Each	
7	Misc. items	LS		
	GST			
	GROSS TOTAL			

1055
29